

WKU Known Asbestos Location List

Always check with WKU Environment, Health Safety @ 270-745-2236 before disturbing a building material on campus.

Locations	Building Materials							Insulating Materials							Notes
	Ceiling Materials	Ceiling Tile	Flooring, Covebase, or Mastic	Hard Plaster	Wall Board/ Joint Compound	Roofing Materials	Roof Flashing	Fire Doors	Pipes and/or Fittings	Water Heater, Tank or Boiler Jacket	Chiller Jacket	Cooling Towers	Packings & Gaskets		
Academic Complex	SAFE	SAFE	A	SAFE	SAFE & 1	SAFE	SAFE	SAFE	A	A	n/a	n/a	presumed	1, 5, 12, 14	
Agra-Expo Center	SAFE	SAFE	A	SAFE	SAFE	A	A	presumed	SAFE	SAFE	n/a	n/a	presumed	5	
Alumni House	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	SAFE	SAFE	n/a	n/a	SAFE		
Barnes-Campbell Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	A	SAFE	SAFE	n/a	presumed		
Baseball Press Box	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	SAFE		
Bates-Runner Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	SAFE		
Bemis Lawrence Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	A	SAFE	SAFE	n/a	presumed		
Cherry Hall	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	presumed	A	SAFE	SAFE	SAFE	presumed	12, 14, 16	
Chestnut Street 1700	SAFE	SAFE	A	SAFE	SAFE	presumed	presumed	n/a	presumed	SAFE	n/a	n/a	n/a	4, 13	
Chestnut Street 1783	SAFE	n/a	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	SAFE	SAFE	n/a	n/a	n/a	4, 8	
Colonial Court Bldg. C	SAFE	SAFE	SAFE	SAFE	SAFE	presumed	presumed	n/a	A	SAFE	n/a	n/a	n/a		
Colonial Court #1	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	n/a		
Colonial Court #2	SAFE	n/a	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	SAFE	SAFE	n/a	n/a	n/a		
Colonial Court #3	SAFE	n/a	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	SAFE	SAFE	n/a	n/a	n/a		
Colonial Court #4	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	n/a		
Colonial Court #5	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	n/a	4, 8, 15	
Colonial Court #6	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	n/a		
Complex Eng & Bio Science	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE		
Cravens Grad. Center	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	SAFE	A	A	SAFE	SAFE	presumed	14, 16	
Dairy Barn	SAFE & 15	n/a	SAFE	SAFE	SAFE	presumed	presumed	n/a	SAFE	SAFE	n/a	n/a	presumed	15	
Diddle Arena	SAFE	SAFE	SAFE	SAFE	SAFE	A	A	SAFE	SAFE	SAFE	SAFE	SAFE	presumed		
Downing Student Union	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	wall mastic	
Environmental Sci. & Tech	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	presumed	5, 6, 12, 14	
Faculty House	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	SAFE	SAFE	n/a	n/a	presumed		
Farm (Green Shop)	presumed	presumed	presumed	presumed	presumed	n/a	n/a	n/a	presumed	presumed	n/a	n/a	presumed		
Farm (Hog Barn)	SAFE	n/a	SAFE	n/a	SAFE & 15	SAFE	SAFE	n/a	SAFE	SAFE	n/a	n/a	n/a	15	
Farm House # 1	presumed	presumed	presumed	presumed	presumed	SAFE	SAFE	n/a	presumed	presumed	n/a	n/a	n/a	presumed	
Farm House # 2	presumed	presumed	presumed	presumed	presumed	SAFE	SAFE	n/a	presumed	presumed	n/a	n/a	n/a	presumed	
Farm House # 3	presumed	presumed	presumed	presumed	presumed	SAFE	SAFE	n/a	presumed	presumed	n/a	n/a	n/a	presumed	
Farm House # 4	presumed	presumed	presumed	presumed	presumed	SAFE	SAFE	n/a	presumed	presumed	n/a	n/a	n/a	presumed	
Farm House # 5	SAFE	n/a	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	SAFE	SAFE	n/a	n/a	n/a	11	
Farm House # 6	presumed	presumed	presumed	presumed	presumed	SAFE	SAFE	n/a	presumed	presumed	n/a	n/a	n/a	presumed	
Felts Log Cabin	n/a	n/a	n/a	n/a	n/a	SAFE	n/a	n/a	SAFE	n/a	n/a	n/a	n/a		
Fine Arts Center	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	A	A	A	SAFE	SAFE	presumed	5, 12	
Forrest Dr. Coal Analysis	SAFE	n/a	n/a	n/a	n/a	SAFE	SAFE	n/a	n/a	n/a	n/a	n/a	n/a		
Foundation Building	SAFE	A	A	SAFE	SAFE	SAFE	SAFE	A	A	SAFE	n/a	n/a	presumed		
Garrett Conference Center	SAFE	SAFE	A	SAFE	SAFE	presumed	presumed	presumed	A	SAFE	SAFE	SAFE	A	15	
Gilbert Hall	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	SAFE	A & 9	SAFE	SAFE	SAFE	presumed	9	
Gordon Wilson Hall	SAFE	SAFE	A	SAFE	presumed	presumed	presumed	A	A	SAFE	n/a	n/a	presumed		
Grise Hall	SAFE	SAFE	A	SAFE	SAFE	A	A	SAFE	A	A	SAFE	SAFE	presumed	14	
Hardin Planetarium	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	SAFE	A	SAFE	n/a	n/a	presumed		
Hazardous Waste Building	n/a	n/a	n/a	n/a	n/a	SAFE	SAFE	SAFE	SAFE	n/a	n/a	n/a	presumed		
Helm Library	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	A	A	SAFE	SAFE	SAFE	presumed	10	
Honors Center	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	n/a	SAFE	SAFE	n/a	n/a	n/a	4	
Hugh Poland Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	A	A	SAFE	n/a	SAFE	presumed	16	
Indoor Batting Bldg.	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	SAFE		
Industrial Ed. Building	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	presumed	SAFE	SAFE	n/a	n/a	presumed	5	
International Center	A	presumed	A	presumed	presumed	presumed	presumed	n/a	presumed	presumed	n/a	n/a	presumed	4	
Intramural Complex	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	SAFE		
Jones Jagers	SAFE	SAFE	A	SAFE	SAFE	presumed	presumed	SAFE	A	SAFE	n/a	n/a	presumed	5, 12, 13, 16	
Keen Hall	SAFE	SAFE	SAFE	SAFE	SAFE	A	A	SAFE	A	SAFE	SAFE	SAFE	presumed	12, 16	
Kentucky Building	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	presumed	A	A	SAFE	A	presumed	5	

WKU Known Asbestos Location List

Always check with WKU Environment, Health Safety @ 270-745-2236 before disturbing a building material on campus.

Locations	Building Materials							Insulating Materials						
	Ceiling Materials	Ceiling Tile	Flooring, Covebase, or Mastic	Hard Plaster	Wall Board/ Joint Compound	Roofing Materials	Roof Flashing	Fire Doors	Pipes and/or Fittings	Water Heater, Tank or Boiler Jacket	Chiller Jacket	Cooling Towers	Packings & Gaskets	Notes
Log Cabin (14th Avenue)	presumed	presumed	presumed	SAFE	SAFE	presumed	presumed	n/a	presumed	presumed	n/a	n/a	presumed	presumed
Mass Media & Tech Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	SAFE	
McCormack Hall	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	presumed	SAFE & 9	SAFE	n/a	presumed	presumed	9, 16
McLean Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	SAFE	
Meredith Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	presumed	
Mimosa Alley 1660	SAFE	SAFE	SAFE	SAFE	SAFE	presumed	presumed	n/a	A	SAFE	n/a	n/a	n/a	8,15
Minton Hall	SAFE	SAFE	SAFE	n/a	SAFE	SAFE	SAFE	presumed	A	SAFE	SAFE	SAFE	presumed	
Nashville Rd 2315 (bookstore)	SAFE	SAFE	SAFE	n/a	SAFE	presumed	presumed	n/a	SAFE	SAFE	n/a	SAFE	presumed	
Nashville Rd 2319 (Farmers Mkt)	SAFE	SAFE	SAFE	SAFE	SAFE	A	A	n/a	SAFE	SAFE	n/a	n/a	presumed	
Normal Drive 1702	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	n/a	SAFE	SAFE	n/a	n/a	n/a	15
Normal Drive 1790	presumed	presumed	A	presumed	presumed	SAFE	SAFE	n/a	presumed	presumed	n/a	n/a	presumed	
North/East Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	SAFE	
Park Street 1716	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	A	presumed	n/a	n/a	presumed	
Parking & Transport Bldg.	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	SAFE	
Pearce Ford Tower	A	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	A	A & 9	SAFE	n/a	n/a	A	9, 12
Physical Plant	SAFE	SAFE	A	SAFE	SAFE	A	A	presumed	A	SAFE	n/a	n/a	presumed	
Police Station	SAFE	SAFE	A	SAFE	SAFE	A	A	presumed	A	SAFE	n/a	n/a	presumed	
Potter Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	presumed	
Preston Health Center	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	presumed	
Regents Ave. 501	SAFE	n/a	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	A	presumed	n/a	n/a	n/a	4
Regents Ave. 503	SAFE	n/a	presumed	SAFE	SAFE	presumed	presumed	n/a	presumed	presumed	n/a	n/a	n/a	presumed
Regents Ave. 513	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	SAFE	SAFE	n/a	n/a	n/a	4
Rodes Harlin Hall	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	SAFE	A & 9	SAFE	SAFE	SAFE	presumed	9
Schneider Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	SAFE	
Science & Tech Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	A	SAFE	n/a	n/a	SAFE	
Smith Stadium East	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	A	SAFE	SAFE	SAFE	n/a	n/a	presumed	
South Campus	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	
South Way 205	presumed	presumed	presumed	presumed	presumed	presumed	presumed	n/a	presumed	presumed	n/a	n/a	presumed	presumed
South/West Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	SAFE	
State Street 1425	presumed	presumed	presumed	presumed	presumed	presumed	presumed	n/a	presumed	presumed	n/a	n/a	presumed	presumed
State Street 1532	SAFE	SAFE	presumed	presumed	presumed	presumed	presumed	n/a	presumed	presumed	n/a	n/a	presumed	4, 13
State Street 1536	presumed	presumed	presumed	presumed	presumed	presumed	presumed	n/a	presumed	presumed	n/a	n/a	presumed	presumed
Steam Dist. System	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	A	n/a	n/a	n/a	presumed	
Steam Plant	SAFE	SAFE	SAFE	SAFE	SAFE	A	A	n/a	A	A	n/a	n/a	presumed	
Supply - Services Bldg.	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	presumed	A	SAFE	n/a	n/a	presumed	
Tate Page Hall	SAFE	SAFE	A	SAFE	SAFE	presumed	presumed	presumed	A	SAFE	n/a	n/a	presumed	5, 10, 13, 14
Taylor Center	SAFE	SAFE	A	SAFE	SAFE	presumed	presumed	SAFE	presumed	SAFE	n/a	n/a	n/a	13
TCCW	SAFE & 2	SAFE	A	SAFE	SAFE	SAFE	SAFE	presumed	A	SAFE	SAFE	A	presumed	2, 5, 7, 12, 14
TCNW	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	presumed	A	SAFE	SAFE	SAFE	presumed	7, 12
U.S. 31-W By-Pass 1818	SAFE	n/a	SAFE	SAFE	SAFE	SAFE & 16	SAFE	n/a	SAFE	SAFE	n/a	n/a	SAFE	8, 15, 16
Van Meter Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	presumed	
Wetherby Admin. Building	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	presumed	A	SAFE	n/a	n/a	presumed	13, 14
WKU Center For R&D	SAFE	SAFE	A	SAFE	SAFE	SAFE	SAFE	presumed	A	SAFE	n/a	n/a	presumed	15, 16
Zacharias Hall	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	SAFE	n/a	n/a	presumed	

"A" - the material is asbestos-containing and should not be disturbed.

"presumed" - the material is presumed to contain asbestos and has not been sufficiently sampled to prove otherwise ~ DO NOT DISTURB ~ without prior approval.

SAFE" - the material is not ACM.

"n/a" - not applicable.

NOTES: Any work to be completed on windows in WKU buildings shall be reviewed individually by Laura Tomlin.

- | | | | |
|--|--|--|---|
| (1) Sound control wall panels in radio & TV studios only | (5) Some lab table tops contain asbestos | (9) Asbestos-containing black pipe-coating | (13) Asbestos lighting/heating insulation |
| (2) Spray applied ceiling in 205, 209 & 211 only | (6) Welding tables may contain asbestos | (10) Asbestos-containing wiring insulation | (14) Asbestos-containing window/door panels |
| (3) Vault ceiling plaster only is asbestos | (7) Asbestos-containing chalkboards | (11) Asbestos-containing asphalt siding | (15) Asbestos cementitious board or siding |
| (4) Asbestos-containing duct or vent insulation/tape | (8) Asbestos cementitious pipe or vent | (12) Asbestos-containing glue-dots | (16) Asbestos-containing caulking |

WKU Known Asbestos Location List

Always check with WKU Environment, Health Safety @ 270-745-2236 before disturbing a building material on campus.

Locations	Building Materials						Insulating Materials						
	Ceiling Materials	Ceiling Tile	Flooring, Covebase, or Mastic	Hard Plaster	Wall Board/ Joint Compound	Roofing Materials	Roof Flashing	Fire Doors	Pipes and/or Fittings	Water Heater, Tank or Boiler Jacket	Chiller Jacket	Cooling Towers	Packings & Gaskets

This list is a review of asbestos data intended for reference use only. An Asbestos Management Request and full NESHAP asbestos survey are required prior to any demolition or renovation activity.

~ This list shall be referenced prior to any work which may disturb any building or insulating materials ~

All black mastics, along with all other suspect materials, are presumed asbestos-containing until sufficient sampling has been completed to prove otherwise.